


ITEM	HOSPITAL GRADE TRANSFORMER				QTY.
	POWER	PRIMARY VOLTAGE	SECONDARY VOLTAGE	FREQUENCY	
1	7.5 KVA	120 VOLTS	60 Hz		1
		208 VOLTS			
		220 VOLTS			
	10 KVA	240 VOLTS			
		480 VOLTS			
2	LINE ISOLATION MONITOR: 120 VOLT (OR 208/-240V SELECTABLE), 60HZ (OR 50HZ SELECTABLE), TOTAL HAZARD INDEX 5mA (OR 2mA SELECTABLE), 20 UA MONITOR HAZARD CURRENT, LCD USER INTERFACE, LINE VOLTAGE INDICATION, ONBOARD EVENT LOG WITH TIME/DATE STAMP, USER SELECTABLE SELF-CALIBRATION PERIOD. OPTIONAL FEATURES: USB DATA INTERFACE AND TRANSFORMER LOAD AND TEMPERATURE MONITORS.				1
3	PRIM MAIN CIRCUIT BREAKER AMP I.C.			AMPS, 2-POLE	1
4	SEC BRANCH CIRCUIT BREAKERS AMP I.C. **16 CIRCUIT MAX.			15 AMP 2 POLE	
				20 AMP 2 POLE	
				30 AMP 2 POLE	
5	RECEPTACLE-DUPLEX, 125V, 20AMP, RED				
6	GROUND JACK RECEPTACLE, TWIST TO LOCK, HAMPDEN 30A				
7	X-RAY VIEWER - TWO GANG, STANDARD FILM ACTIVATED				1
8	SURGICAL CLOCK - DIGITAL TYPE, 12 OR 24 HOUR				1
9	SURGICAL TIMER - DIGITAL TYPE				1
10	TIMER CONTROL				1
11	CLOCK CONTROL				1
12	BACKBOX, 467-206-736				1

REFERENCE ONLY

TOTAL REQUIRED _____

FOR:		S.O. NUM.:	
STD.	ACAD STD.: SFPL11005.dwg	TITLE/DESCRIPTION: SURGICAL FACILITY PANEL TYPE: SFP	
B.O.M.:		DFTR: JJM	DATE: 03/28/11
 <p>POST GLOVER LIFELINK 167 GAP WAY ERLANGER, KY U.S.A. 41018 (859) 283-5900 COPYRIGHT © 2011</p>		DWG. NO.: SFPL11005	REV.: 00
<small>THIS DOCUMENT AND THE INFORMATION IT CONTAINS ARE THE PROPERTY OF POST GLOVER LIFELINK. IT IS DISCLOSED FOR THE PURPOSE FOR WHICH IT IS FURNISHED AND SHALL NOT BE DUPLICATED OR DISTRIBUTED.</small>			